

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. _____

Date : 21/03/2025

It is certified that an inspection team headed by Sutripta Mahalanobish,
Junior Engineer (BP) (Name of Officers
with designation) from Domjur Development Block (Name of
Department/Office) inspected the Delhi Public School, Horraah
Vill + P.O + P.S - Domjur, Horraah - 711405 (Name & Address of
the School) on 12.03.2025 and found that the Delhi Public School,
Horraah (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of upto 31.03.2026

Signature with Seal

[Signature] 21/03/2025
Junior Engineer
Domjur Dev. Block

Name

SUTRIPTA MAHALANOBISH

Designation

JUNIOR ENGINEER (BP)

To

Delhi Public School, Horraah
Vill + P.S + P.O - Domjur, Horraah - 711405

(Name & Address of the Institution)

Results of Chemical Examination

DISTRICT LABORATORY UNDER HOWRAH DIVISION
PUBLIC HEALTH ENGINEERING DIRECTORATE




DATE OF REPORT	13.03.2025
SAMPLE NO.	5011
SAMPLE SOURCE	Drinking water from Delhi Public School, Howrah.
SAMPLE COLLECTED BY	Somnath Mukherjee (Staff of this School)
DATE OF COLLECTION	12.03.2025
DATE OF TESTING	12.03.2025

SL NO.	Parameters	Expressed As	Recommended Drinking Water Quality as per IS 10500: 2012 (Second Revision)		RESULT
			Acceptable Limit (Max)	Permissible Limit (Max)	
1.	pH	-	6.5 - 8.5	No relaxation	7.83
2.	Turbidity	NTU	1	5	0.56
3.	Total Dissolved Solid	mg/l	500	2000	425
4.	Total Hardness	mg/l	200	600	195
5.	Chloride	mg/l	250	1000	79.41
6.	Iron	mg/l	1.0	No relaxation	0.01
7.	Manganese	mg/l	0.1	0.3	-
8.	Arsenic	mg/l	0.01	No relaxation	BDL
9.	Salinity	ppt	-	-	0.3

N.B: Sample was not collected by the department, hence source and depth not confirmed.

Chemist
Howrah Dist. Lab
PHE Dte

Asst. Engineer
Howrah Division
PHE Dte.



Results of Bacteriological Examination

DISTRICT LABORATORY UNDER HOWRAH DIVISION PUBLIC HEALTH ENGINEERING DIRECTORATE

DATE OF REPORT	13.03.2025
SAMPLE NO	5011
SAMPLE SOURCE	Drinking water from Delhi Public School, Howrah.
SAMPLE COLLECTED BY	Somnath Mukherjee (Staff of School)
DATE OF COLLECTION	12.03.2025
PERIOD OF TESTING	12.03.2025-13.03.2025

SL. NO.	PARAMETERS	DESIRABLE LIMIT	RESULT
1	Total Coliforms (CFU/100ml)	Nil	Nil (Not detected)
2	Faecal Coliforms (CFU/100ml)	Nil	Nil (Not detected)

N.B: Sample was not collected by the department, hence source and depth not confirmed.

Bacteriologist
Howrah Dist. Lab
PHE Dte.

Asst. Engineer
Howrah Division
PHE Dte.