

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. _____

Date : 13-2-2023

It is certified that an inspection team headed by Arundhati Roy,
SAE (BP). (Name of Officers
with designation) from Damjun BDO (Name of
Department/Office) inspected the Delhi Public School, Howrah. Vill.+ P.O.+
P.S. - Damjun, Howrah - Amta Road, Howrah-711405 (Name & Address of
the School) on 13-2-23 and found that the Delhi Public School,
Howrah. (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of upto 31st March, 2024.

Signature with Seal : A. Roy 13/2/23

Name : Arundhati Roy
Designation : Sub.-Asst. Engineer
(B. P. Dev. for Block)

To

Delhi Public School, Howrah.
Vill.+ P.O.+ P.S. - Damjun, Howrah - Amta
Road, Pin: 711405

(Name & Address of the Institution)

Results of Chemical Examination

DISTRICT LABORATORY UNDER HOWRAH DIVISION
PUBLIC HEALTH ENGINEERING DIRECTORATE



DATE OF REPORT	03.02.2023
SAMPLE NO.	3606
SAMPLE SOURCE	Drinking Water From Delhi Public School, (Aquaguard water), Domjur, Howrah.
SAMPLE COLLECTED BY	Suranjan Kabasi
DATE OF COLLECTION	02.02.2023
DATE OF TESTING	02.02.2023

SL NO.	Parameters	Expressed As	Recommended Drinking Water Quality as per IS 10500: 2012 (Second Revision)		RESULT
			Acceptable Limit (Max)	Permissible Limit (Max)	
1.	pH	-	6.5 - 8.5	No relaxation	7.68
2.	Turbidity	NTU	1	5	0.24
3.	Total Dissolved Solid	mg/l	500	2000	416
4.	Total Hardness	mg/l	200	600	240
5.	Iron	mg/l	1.0	No relaxation	0.02
6.	Manganese	mg/l	0.1	0.3	0.01
1	Chloride	mg/l	250	1000	21.44
8.	Arsenic	mg/l	0.01	No relaxation	BDL
9.	Salinity	ppt	-	-	0.3

Chemist
Howrah Dist. Lab
PHE Dte.

Asst. Engineer
Howrah Division
PHE Dte.

Executive Engineer
Howrah Division
PHE Dte.





Results of Bacteriological Examination


DISTRICT LABORATORY UNDER HOWRAH DIVISION
PUBLIC HEALTH ENGINEERING DIRECTORATE

DATE OF REPORT	03.02.2023
SAMPLE NO.	3606
SAMPLE SOURCE	Drinking Water From Delhi Public School, (Aquaguard water), Domjur, Howrah.
SAMPLE COLLECTED BY	Suranjan Kabasi
DATE OF COLLECTION	02.02.2023
PERIOD OF TESTING	02.02.2023 - 03.02.2023

SL. NO.	PARAMETERS	DESIRABLE LIMIT	RESULT
1	Total Coliforms (CFU/100ml)	Nil	Nil (Not detected)
	Faecal Coliforms (CFU/100ml)	Nil	Nil (Not detected)


Bacteriologist
Howrah Dist. Lab
PHE Dte.


Asst. Engineer
Howrah Division
PHE Dte.


Executive Engineer
Howrah Division
PHE Dte.